



中国国家强制性产品认证证书

证书编号: 2014010309692173

委托人名称、地址

安科瑞电气股份有限公司
上海市嘉定区育绿路253号

生产者(制造商)名称、地址

安科瑞电气股份有限公司
上海市嘉定区育绿路253号

生产企业名称、地址

江苏安科瑞电器制造有限公司
江阴市南闸镇东盟路5号

产品名称和系列、规格、型号

电动机保护器

ARD3T Ui:660V;Ue:AC380V/660V; Ie:0.4-2.0A, 1.6-6.3A, 6.3-25A, 25-100A, 63-250A; 脱扣级别:10A, 10, 20, 30;3P;1P20; 配用的辅助触头(4NO):Ith:6A;AC-15;Ue:AC220V/Ie:5A;型号详见附录

产品标准和技术要求

GB 14048.4-2010

上述产品符合强制性产品认证实施规则
CNCA-01C-011:2007的要求,特发此证。

发证日期: 2014年05月08日

有效期至: 2019年05月08日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 0841163



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010309692173

NAME AND ADDRESS OF THE APPLICANT

ACREL Co., Ltd.
No. 253 YuLv Road, JiaDing District, ShangHai City

NAME AND ADDRESS OF THE MANUFACTURER

ACREL Co., Ltd.
No. 253 YuLv Road, JiaDing District, ShangHai City

NAME AND ADDRESS OF THE FACTORY

Jiangsu ACREL Electric MFG. Co., Ltd.
No. 5 DongMeng Road, NanZha Town, JiangYin City

NAME, MODEL AND SPECIFICATION

Motor Protector

ARD3T Ui:660V;Ue:AC380V/660V; Ie:0.4-2.0A, 1.6-6.3A, 6.3-25A, 25-100A, 63-250A; Tripping Class:10A, 10, 20, 30;3P;IP20; Attached Auxiliary Contacts (4NO):Ith:6A;AC-15;Ue:AC220V/Ie:5A;See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.4-2010

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: May.08, 2014 Date of expiry: May.08, 2019

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>



Q 0841163