



# 中国国家强制性产品认证证书

证书编号: 2012010301539056

## 委托人名称、地址

安科瑞电气股份有限公司  
上海市嘉定区育绿路253号

## 生产者(制造商)名称、地址

安科瑞电气股份有限公司  
上海市嘉定区育绿路253号

## 生产企业名称、地址

江苏安科瑞电器制造有限公司  
江阴市南闸街道东盟路5号

## 产品名称和系列、规格、型号

隔离电源柜(低压成套开关设备)

GGF-0 主母线: InA=80A~63A, Icw=3kA; Ue=380V/220V, Ui=380V; 50Hz; IP31

## 产品标准和技术要求

GB 7251.12-2013

上述产品符合强制性产品认证实施规则  
CNCA-C03-01: 2014的要求, 特发此证。

发证日期: 2017年02月08日

有效期至: 2022年02月08日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2012年04月25日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1611447





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2012010301539056

## NAME AND ADDRESS OF THE APPLICANT

ACREL Co., Ltd.  
No.253 YuLv Road, JiaDing District, ShangHai City

## NAME AND ADDRESS OF THE MANUFACTURER

ACREL Co., Ltd.  
No.253 YuLv Road, JiaDing District, ShangHai City

## NAME AND ADDRESS OF THE FACTORY

Jiangsu ACREL Electric MFG. Co., Ltd.  
No.5 DongMeng Road, NanZha Street, JiangYin City

## NAME, MODEL AND SPECIFICATION

Low-voltage Switchgear Assemblies

GGF-0 主母线:InA=80A~63A, Icw=3kA;Ue=380V/220V, Ui=380V;50Hz;IP31

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 7251.12-2013

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C03-01:2014).

Date of issue: Feb.08,2017      Date of expiry: Feb.08,2022

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Apr.25,2012

This certificate can be verified through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1611447