



中国国家强制性产品认证证书

证书编号: 2013010301632947

委托人名称、地址

安科瑞电气股份有限公司
上海市嘉定区育绿路253号

生产者(制造商)名称、地址

安科瑞电气股份有限公司
上海市嘉定区育绿路253号

生产企业名称、地址

江苏安科瑞电器制造有限公司
江阴市南闸镇东盟路5号

产品名称和系列、规格、型号

综合柜(低压成套开关设备)

AZG 主母线: In=630A~100A, Icw=15kA; Ue=400V/230, Ui=660V; 50Hz; IP54

产品标准和技术要求

GB 7251.1-2005

上述产品符合强制性产品认证实施规则
CNCA-01C-010: 2013的要求, 特发此证。

发证日期: 2014年05月20日

有效期至: 2018年08月01日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2013年08月01日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 0922748



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2013010301632947

NAME AND ADDRESS OF THE APPLICANT

ACREL Co., Ltd.
No.253 YuLv Road, JiaDing District, ShangHai City

NAME AND ADDRESS OF THE MANUFACTURER

ACREL Co., Ltd.
No.253 YuLv Road, JiaDing District, ShangHai City

NAME AND ADDRESS OF THE FACTORY

Jiangsu ACREL Electric MFG. Co., Ltd.
No.5 DongMeng Road, NanZha Town, JiangYin City

NAME, MODEL AND SPECIFICATION

Low-voltage Switchgear Assemblies

AZG 主母线:In=630A~100A, Icw=15kA;Ue=400V/230, Ui=660V;50Hz;IP54

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 7251.1-2005

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-010:2013).

Date of issue: May.20,2014 Date of expiry: Aug.01,2018

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Aug.01,2013

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nanshuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 0922748